



# Dahanu Rubber Gloves Manufacturing Co.

MANUFACTURERS OF ELCTRICAL SHOCKPROOF HAND GLOVES

Regd. T. M. No. 1928806


## Test Certificate

E-mail : gloves@rtcogl.in

Date \_\_\_\_\_

To,

M/s. \_\_\_\_\_

This is to certify that, Natural Rubber Latex  seamless Hand Gloves for Electrical purpose.  
supplied to you vide our Bill No. \_\_\_\_\_ dated \_\_\_\_\_ were tested in our laboratory and found confirming to I. S.  
Specification 4770 - 1991, EN - 60903, IEC 60903.

Following tests were performed for the LOT of \_\_\_\_\_ PAIRS SIZE \_\_\_\_\_ m.m. Batch No. \_\_\_\_\_

- 1) Test Potential at 33000 Volts, Working Voltage 17000 Volts. R.M.S. 50 cycle per Second frequency.  
The maximum leakage Current was 7.0 milliamperers.
- 2) Tensile strength average 190 Kgf/cm<sup>2</sup>  
After ageing test at 70° ± 1° C Tensile strength 180 Kgf.Cm<sup>2</sup>
- 3) Elongation at Break 900 percent average.  
The ageing test at 70° ± 1° C Elongation at Break 800 Percent
- 4) Puncture resistance 22.5 kN/m.
- 5) Best Before 12 months from the date of Manufacturing.

Tested By

For DAHANU RUBBER GLOVES MANUFACTURING CO.

**For Dahanu Rubber Gloves Manufacturing Co.**

*M/K*  
Proprietor

**Proprietor**