



Dahanu Rubber Gloves Manufacturing Co.

MANUFACTURERS OF ELECTRICAL SHOCKPROOF HAND GLOVES

Regd. T. M. No. 1928806


E-mail : gloves@rtcogl.in

Test Certificate

To,

Date _____

M/s. _____

This is to certify that, Natural Rubber Latex  seamless Hand Gloves for Electrical purpose. supplied to you vide our Bill No. _____ dated _____ were tested in our laboratory and found confirming to I. S. Specification 4770 - 1991, EN - 60903, IEC 60903.

Following tests were performed for the LOT of _____ PAIRS SIZE _____ m.m. Batch No. _____

1) Test Potential at 11000 Volts, Working Voltage 1100 Volts. R.M.S. 50 cycle per Second frequency.
The maximum leakage Current was 4.6 milliamperers.

2) Tensile strength average 190 Kgf/cm²
After ageing test at 70° ± 1° C Tensile strength 180 Kgf.Cm²

Tested By

3) Elongation at Break 900 percent average.
The ageing test at 70° ± 1° C Elongation at Break 800 Percent

For DAHANU RUBBER GLOVES MANUFACTURING CO.

4) Puncture resistance 24.7 kN/m.

For Dahanu Rubber Gloves Manufacturing Co.

5) Best Before 12 months from the date of Manufacturing.

Mk
Proprietor

Proprietor