



# Dahanu Rubber Gloves Manufacturing Co.

MANUFACTURERS OF ELECTRICAL SHOCKPROOF HAND GLOVES

Regd. T. M. No. 1928806


## Test Certificate

E-mail : gloves@rtcogl.in

To,

Date \_\_\_\_\_

M/s. \_\_\_\_\_

This is to certify that, Natural Rubber Latex  seamless Hand Gloves for Electrical purpose. supplied to you vide our Bill No. \_\_\_\_\_ dated \_\_\_\_\_ were tested in our laboratory and found confirming to I. S. Specification 4770 - 1991, EN - 60903, IEC 60903.

Following tests were performed for the LOT of \_\_\_\_\_ PAIRS SIZE \_\_\_\_\_ m.m. Batch No. \_\_\_\_\_

1) Test Potential at 5000 Volts, Working Voltage 650 Volts. R.M.S. 50 cycle per Second frequency.  
The maximum leakage Current was 4.0 milliamperers.

2) Tensile strength average 190 Kgf/cm<sup>2</sup>  
After ageing test at 70° ± 1° C Tensile strength 180 Kgf.Cm<sup>2</sup>

Tested By

3) Elongation at Break 900 percent average.  
The ageing test at 70° ± 1° C Elongation at Break 800 Percent

For DAHANU RUBBER GLOVES MANUFACTURING CO.

*For Dahanu Rubber Gloves Manufacturing Co.*

4) Puncture resistance 24.4 kN/m.

5) Best Before 12 months from the date of Manufacturing.

*Mk*  
Proprietor

*Proprietor*